

Public Washroom Accessibility Checklist

In regards to the public washrooms in your building, have you considered:

- Grab bars in your bathrooms for the toilets?
- Adequate space beside toilets for lateral transfer from mobility aids?
- Adequate knee space under sinks for people using mobility aids?
- Placing your soap dispensers, paper towel holders, and mirrors at a height that will allow easy access for people using mobility aids?
- Having a raised (tactile) male or female sign on public bathrooms?
- Having at least one public washroom that is fully accessible for people using mobility devices, marked with the international symbol for accessibility?
- A "D" style handle on both sides of the bathroom cubicle door?